



---

**DOROT MANAGEMENT CONTROL VALVES LTD , KIBBUTZ DOROT MOBILE POST HOF  
ASHKELON 79175 ISRAEL. Tel: 972-8-6808848. Fax: 972-8-6808751 E-mail Dorotxp@netvision.net.il**

---

Date: 12/05/2015

## *Test Certificate*

*Here is to certify that series "100" models 30U, 44, 87, 77 and 68 valves withstands the following tests:*


**Test procedure type c – class VI, according to:  
Standard ANSI/FCI 70-2-2006 –  
Fluid controls standard: Control valve seat leakage.**

**Test Pressure: 3.5 bar**

**Tested samples valve sizes: 1 1/2", 2", 2 1/2", 3", 4", 6", 8", 10" & 12"**

**Test Result: Passed**

Best regards,

  
Sami Bohdana  
Quality Assurance  
Manager